Abalone Coast Analytical, Inc
141 Suburban Road, Suite C-1 San Luis Obispo CA, 93401
Phone: 595-1080 Fax: 595-1080
ELAP #2661

Order #: 18-8355
Date/Time Rec'd: 12/27/18 1527

PRO H20
PO Box 5055
Paso Robles, CA 93447

Contact: Scott McKenzie
Phone: 805-674-8674
Sampler: Mike Barba

Project: **Agzone**

Sample #	Sample Description	Date / Time	Analysis	Method	Result	Units	RL	Completed
-1	**11520 Tule Elk Ln**	**12/27/18 1045**	Total Coliform	SM 9223 B.	**Absent**	/100ml	1	**12/28/18**
			E-coli	IDEXX	**Absent**	/100ml	1	**12/28/18**
-2	**11525 Tule Elk Ln**	**12/27/18 1100**	Total Coliform	SM 9223 B.	**Absent**	/100ml	1	**12/28/18**
			E-coli	IDEXX	**Absent**	/100ml	1	**12/28/18**
-3	**11330 Tule Elk Ln**	**12/27/18 1115**	Total Coliform	SM 9223 B.	**Absent**	/100ml	1	**12/28/18**
			E-coli	IDEXX	**Absent**	/100ml	1	**12/28/18**

This sample passes water quality standards for Total Coliform and E. Coli Bacteria

Report Completion Date: **12/28/18**

Reviewed: Sean Rogers

Sean Rogers, Lab Director

Definitions:

Absent = Less than 1 CFU/100mLs
Present = 1
CFU = Colony Forming Unit
RL = Reporting Limit

State of California CDPH ELAP 2661

Coliform are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

The presence of Fecal coliforms and/or *E. coli* indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.